

FFW OPTION CODES

CODE	DESCRIPTION	LIST ADDER/ (DEDUCT)
000	STANDARD FEATURES: FULLY INSULATED CABINET, 40 VA TRANSFORMER, GALVANIZED STEEL CABINET WITH PAINTED ACCESS PANELS, DIRECT DRIVE FLEX MOUNTED MULTI SPEED BLOWER, FACTORY INSTALLED CIRCULATOR PUMP AND CHECK VALVE, CHECK STYLE FLORATER USED FOR A/C AND HEAT PUMPS, PRIMARY & SECONDARY CONDENSATE DRAIN, ALL DRAIN CONNECTIONS 3/4" FPT WITH PLUGS IN ALL DRAINS, CIRCUIT BREAKER DISCONNECT, END OR BOTTOM RETURN AIR POSITION ,FAN TIME DELAY RELAY, FREEZE STAT INSTALLED, BUILT IN MOUNTING TABS FOR CEILING & FURR DOWN MOUNTING, HIGH EFFICIENCY COPPER TUBE / ALUMINUM FIN COIL, INCLUDES SUPPLY AIR PLENUM #SAP-3 AND LOUVERED CEILING ACCESS PANEL #CAD-5WL (18-24) AND #CAD-7L (30-36)	\$0
001	WITHOUT PLENUM #SAP-3	(\$54)
002	TERMINAL BLOCK	(\$12)
003	Yet to be determined	\$0
004	SOLID CEILING ACCESS PANEL #CAD7S , SUPPLY AIR PLENUM #SAP-3 AND SOLID BOTTOM DOOR	\$0
005	STANDARD -000 UNIT WITHOUT #CAD-7(S/L) ACCESS PANEL	(\$34)
006	WITHOUT PLENUM #SAP-3, TERMINAL BLOCK	(\$66)
013	HOSE BIB AND CAP, TERMINAL BLOCK	\$72
014	HOSE BIB AND CAP, TERMINAL BLOCK, REMOVED FREEZE STAT EFFECTIVE 12/01/06 AS IT IS NOW IN THE STANDARD USE OPTION CODE #013	\$72
015	WITHOUT PLENUM (SAP-3), HOSE BIB AND CAP, TERMINAL BLOCK, REMOVED FREEZE STAT EFFECTIVE 12/01/06 AS IT IS NOW IN THE STANDARD	(\$18)
016	LESS DX COOLING COIL 18/24 ONLY	(\$72)
017	HOSE BIB AND CAP, TERMINAL BLOCK, LESS ACCESS PANEL	\$8
018	LESS CEILING ACCESS DOOR, LESS SUPPLY AIR PLENUM, TERMINAL BLOCK	(\$68)
019	LESS DX COOLING COIL 18/24 ONLY, WITHOUT PLENUM #SAP-2	(\$100)
020	LESS DX COOLING COIL 30/36 ONLY	(\$84)